

PROHLÁŠENÍ O VLASTNOSTECH

DLE NAŘÍZENÍ EVROPSKÉHO PARLAMENTU A RADY EU č. 305/2011
kterým se stanoví harmonizované podmínky pro uvádění stavebních výrobků na trh
číslo CPR 004_2013

- 1. Kód typu výrobku:** JA-80S
2. Název výrobku: Bezdrátový detektor požáru
3. Zamyšlené použití: Detekce požáru v budovách
4. Výrobce
Obchodní jméno: JABLOTRON ALARMS a.s.
Sídlo: Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou
IČ: 28668715
5. Pověřený zástupce: Nestanoven
6. Posouzení a ověření stálosti vlastností: Systém 1
7. Provedení typové zkoušky a počáteční inspekce a řízení výroby:
EVPU a.s., Trenčianská 9, Nová Dubnica, Slovenská republika, číslo oznámeného subjektu 1293, vydáno
osvědčení o stálosti vlastností **CE 1293-CPD-0263**.
8. Evropské technické posouzení: Neaplikováno
9. Vlastnosti uvedené v prohlášení:

Základní charakteristiky	Vlastnost	EN 54-7:2000 + A1:2002	EN 54-5:2000 +A1:2002
Jmenovité aktivační podmínky/citlivost, zpoždění reakce a funkce v podmínkách požáru	vyhovující	4.8, 5.2 - 5.4, 5.6, 5.7, 5.18	4.2, 4.3, 5.2 - 5.6, 5.8
Provozní spolehlivost	vyhovující	4.2 - 4.7, 4.9 - 4.11	4.4 - 4.11
Kolísání napájecího napětí	vyhovující	5.5	5.7
Stálost provozní spolehlivosti a zpoždění reakce a odolnosti vůči teple	vyhovující	5.8, 5.9	5.9, 5.10
Stálost provozní spolehlivosti: odolnost vůči vibracím	vyhovující	5.13 - 5.16	5.14 - 5.17
Stálost provozní spolehlivosti: odolnost vůči vlhkosti	vyhovující	5.10, 5.11	5.11 - 5.12
Stálost provozní spolehlivosti: odolnost vůči korozi	vyhovující	5.12	5.13
Stálost provozní spolehlivosti: elektrická stabilita	vyhovující	5.17	5.18

- 10. Vlastnost výrobku uvedeného v bodě 1 a 2 je ve shodě s vlastnostmi uvedenými v bodě 9.**
Toto prohlášení o vlastnostech je vydáno na výhradní odpovědnost výrobce uvedeného v bodě 4.

V Jablonci nad Nisou, dne: 1.7.2013

Miroslav Jarolím
ředitel



Tel: 483 559999
Fax: 483 313183
E-mail: prodej@jablotron.cz

DECLARATION OF PERFORMANCE

ACCORDING TO REGULATION EU No 305/2011 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL
laying down harmonised conditions for the marketing of construction products

No. CPR_004_2013

- 1. Product identification code:** JA-80S
2. Type identification: Wireless detector
3. Intended use: Fire detection in buildings
4. The manufacturer
Name: JABLOTRON ALARMS a.s..
Address: Pod Skalkou 4567/33, Jablonec nad Nisou, Czech Republic, Postcode: 466 01
Company number: CZ28668715
5. Authorized representative: Not applied
6. Assessment and verification of constancy of performance: System 1
7. Performed type testing and the initial inspection of the manufacturing plant and of the factory production control:
EVPÚ a.s., Trenčianská 9, Nová Dubnica, Slovak Republic, notified body 1293, issued certificate of constancy performance **CE 1293-CPD-0263**.
8. European Technical Assessment: Not apply
9. Declared performance:

Essential characteristic	Performance	EN 54-7:2000 + A1:2002	EN 54-5:2000 + A1:2002
Nominal activation conditions/sensitivity, response delay and performance under fire condition	pass	4.8, 5.2 - 5.4, 5.6, 5.7, 5.18	4.2, 4.3, 5.2 - 5.6, 5.8
Operational reliability	pass	4.2 - 4.7, 4.9 - 4.11	4.4 - 4.11
Tolerance to supply voltage	pass	5.5	5.7
Durability of operational reliability, response delay, temperature resistance	pass	5.8, 5.9	5.9, 5.10
Durability of operational reliability, vibration resistance	pass	5.13 - 5.16	5.14 - 5.17
Durability of operational reliability, humidity resistance	pass	5.10, 5.11	5.11 - 5.12
Durability of operational reliability, corrosion resistance	pass	5.12	5.13
Durability of operational reliability, electrical stability	pass	5.17	5.18

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer.

Place: Jablonec nad Nisou, Date: 1.7.2013

Miroslav Jarolím
Managing director



Phone: +420 483 559 911
Fax: +420 483 313 183
E-mail: export@jablotron.cz